

School District Type	School Name	SamplePointName (Source_Name)	Initial Result		Repeat Result		Confirmatory		2nd Confirmatory		For Confirmatory Level >15 ppb, Investigative Sample Result										Post-corrective				
			Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Sample Time for Sample #2	Sample #2 Pb (µg/L)	Sample #3 Pb (µg/L)	Sample #4 Pb (µg/L)	Sample #5 Pb (µg/L)	Sample #6 Pb (µg/L)	Sample #7 Pb (µg/L)	Sample #8 Pb (µg/L)	Sample #9 Pb (µg/L)	Sample #10 Pb (µg/L)	SampDesc (Location_Comments)	Comments	Sample Date	Pb (µg/L)
		Holy Name Elementary - SPECIAL SAMPLE	25-Jan-18	< 1																		Site #36 - South Drinking Fountain #2 (Right)	Used on initial sampling date of 12/9/17		
		Holy Name Elementary - SPECIAL SAMPLE	19-Jan-18	3.8																		Site #50 - Flanagan Center Kitchen	Used on initial sampling date of 12/9/17		
		Holy Name Elementary - SPECIAL SAMPLE	19-Jan-18	< 1																		Bottle Refill Station / Drinking Fountain COMBO - Between Chinese Language Room and Room 4, across f			
		Holy Name Elementary - SPECIAL SAMPLE	19-Jan-18	< 1																		Bottle Refill Station / Drinking Fountain COMBO - Between Room 2A & ART Room, across from Religious E			
		Holy Name Elementary - SPECIAL SAMPLE	19-Jan-18	< 1																		Bottle Refill Station / Drinking Fountain COMBO - Between Room 2A & ART Room, across from Religious E			
		Holy Name Elementary - SPECIAL SAMPLE	25-Jan-18	17	22-Feb-18	14	7-Mar-18	14														Sink Faucet - Inside Kindergarten Classroom			
		Holy Name Elementary - SPECIAL SAMPLE	19-Jan-18	< 1																		Bottle Refill Station / Drinking Fountain COMBO - Between Chinese Language Room and Room 4, across f			
Catholic	Immaculate Conception Academy	Immaculate Conception Academy - Site A	12-Apr-18	< 1																		Basement Cafeteria across boiler room Bottle refill station.			
		Immaculate Conception Academy - Site B	12-Apr-18	2.7																		1st Floor inside Faculty Lounge. Kitchen Sink Faucet.			
		Immaculate Conception Academy - Site C	12-Apr-18	6																		2nd Floor in Restroom in south end Gym. Sink Faucet.			
		Immaculate Conception Academy - Site D	12-Apr-18	2.1																		Herbst Hall 1st Floor by student center. Bottle refill station.			
		Immaculate Conception Academy - Site E	12-Apr-18	< 1																		1st FI Girl Restrm Left most sink Drinking fountain			
Catholic	Mercy High School	Mercy High School - Site A	12-Apr-18	2.1																		4th Floor inside room 432. Kitchen sink faucet			
		Mercy High School - Site B	12-Apr-18	< 1																		3rd flr. next to rm 312, across from rm 313, drinking fountain			
		Mercy High School - Site C	12-Apr-18	< 1																		2nd flr. next to rm 218, across from rm 213 drinking fn fill stn.			
		Mercy High School - Site D	12-Apr-18	4.3																		1st flr. nxt to womens rm, rm 104 drinking fountain fill station			
		Mercy High School - Site E	12-Apr-18	< 1																		1st flr. in the rotunda hallway, on the west side of bldg. df			
Catholic	Mission Dolores Academy	Mission Dolores Academy - Site A	29-Mar-18	< 1																		1xDF; MB 1st Flr. ACR 1st Grade Clsrm NXT 2nd Grade Clsrm			
		Mission Dolores Academy - Site B	29-Mar-18	< 1																		1xDF; MB 2nd Flr. BTWN 7th & 8th Grade Clsrms			
		Mission Dolores Academy - Site C	29-Mar-18	< 1																		2sets 4xDF(Leftmost of right set); School Yard			
		Mission Dolores Academy - Site D	29-Mar-18	< 1																		2xDF(upperright); Gym - East Entry			
		Mission Dolores Academy - Site E																				No sample on 3/29/18 due to no flow. 4 samples is fine as confirmed by Paul Recktenwald			
Catholic	Our Lady of Visitation Elementary School	Our Lady of Visitation Elementary School - Site A	29-Mar-18	4.2																		Main Building. In "boy's restroom hallway" Dual DF. Sample Upper left fountain.			
		Our Lady of Visitation Elementary School - Site B	29-Mar-18	15																		Main Building. In "Girl's restroom hallway" Dual DF. Sample upper left.			
		Our Lady of Visitation Elementary School - Site C	29-Mar-18	< 1																		Main Building. Inside kindergarten room. sink with DF. Sample DF.			
		Our Lady of Visitation Elementary School - Site D	29-Mar-18	< 1																		Main Building. Inside teacher's lounge sink, turn faucet right for cold water.			
		Our Lady of Visitation Elementary School - Site E	29-Mar-18	1																		Gym. Parish kitchen sink. Sample right knob for cold water. Sample large sink on the left.			
Catholic	Sacred Heart Cathedral Preparatory	Sacred Heart Cathedral Preparatory - Site A	29-Mar-18	< 1																		Student life center. First floor, outside the cafeteria left of the entryway. DF w/ bottle filling s			
		Sacred Heart Cathedral Preparatory - Site B	29-Mar-18	< 1																		La Salle Building. In hallway between library & chapel on 6th floor. DF Bottle filling station.			
		Sacred Heart Cathedral Preparatory - Site C	29-Mar-18	4.6																		La Salle building. 5th floor across room 502 between restroom doors. single DF			
		Sacred Heart Cathedral Preparatory - Site D	29-Mar-18	< 1																		La Salle building. 1st floor across room 106. between restroom doors. dual DF. Sample DF.			
		Sacred Heart Cathedral Preparatory - Site E	29-Mar-18	< 1																		La Salle Building. 3rd floor, around corner from attendance office, just inside la salle building en			
Catholic	Saint Anne School	Saint Anne School - Site A	31-Jan-18	< 1																		Convent, Pre-K kitchenette along wall. Sink- Sample cold tap on the right.			
		Saint Anne School - Site B	31-Jan-18	1.7																		Far left drinking fountain of triple fountain unit along wall outside preschool in yard			
		Saint Anne School - Site C	31-Jan-18	< 1																		Lower drinking fountain in upper cafeteria in basement of Main Building			
		Saint Anne School - Site D	31-Jan-18	< 1																		Stainless steel drinking fountain next to Room 3-1 on 1st floor of Main Building			
		Saint Anne School - Site E	31-Jan-18	< 1																		Right stainless steel drinking fountain above small panel door and near to Room 4-1 on 2nd floor of			
Catholic	Saint Anthony-Immaculate Conception	Saint Anthony-Immaculate Conception - Site A	7-Feb-18	< 1																		Drinking fountain next to hall closet and across from Room 300 on 1st floor of Main Building			
		Saint Anthony-Immaculate Conception - Site B	7-Feb-18	< 1																		Drinking fountain next to Room 304 Roof and across from Grade 6 room on 2nd floor of Main Building			
		Saint Anthony-Immaculate Conception - Site C	7-Feb-18	< 1																		Drinking fountain between closet and service counter in cafeteria at basement level of Main Building			
		Saint Anthony-Immaculate Conception - Site D	7-Feb-18	2.5																		Middle drinking fountain of triple unit on north side (Cesar Chavez St.) of Upper Yard outside Main			
		Saint Anthony-Immaculate Conception - Site E	7-Feb-18	< 1																		Middle drinking fountain by flagpole on south (Precita Ave) side of Upper Yard outside Main Building			
Catholic	Saint Brigid School	Saint Brigid School - Site A	1-Feb-18	1.6																		Lower drinking fountain across from basketball courts and next to courtyard exist near Boys' Room			
		Saint Brigid School - Site B	1-Feb-18	< 1																		Drinking fountain between cafeteria entrance and stairways on ground floor in Main Building			
		Saint Brigid School - Site C	1-Feb-18	< 1																		Drinking fountain between Room 1K and stairways on 1st floor in Main Building			
		Saint Brigid School - Site D	1-Feb-18	< 1																		Drinking fountain between faculty room and stairways on 2nd floor in Main Building			
		Saint Brigid School - Site E	1-Feb-18	< 1																		Drinking fountain between Reading Specialist Room and stairway on 3rd floor in Main Building			
Catholic	Saint Finn Barr Catholic School	Saint Finn Barr Catholic School - Site A	14-Feb-18	< 1																		Lower drinking fountain between Boys' Restroom and supply room on 1st floor of Main Building	One site, confirmed by school rep LaChon on 2/14/18		
		Saint Finn Barr Catholic School - Site B																							
		Saint Finn Barr Catholic School - Site C																							
		Saint Finn Barr Catholic School - Site D																							
		Saint Finn Barr Catholic School - Site E																							
Catholic	Saint James School	Saint James School - Site A	23-Jan-18	< 1																		Upper drinking fountain at 1st floor stairs landing in Main Building			
		Saint James School - Site B	23-Jan-18	5.9																		Cold water tap at sink inside Kindergarten Room in Main Building			
		Saint James School - Site C	23-Jan-18	< 1																		Drinking fountain at 2nd floor stairs landing in Main Building			
		Saint James School - Site D	23-Jan-18	< 1																		Middle fountain of trio unit in school yard and near to Boys' bathroom at north exit			
		Saint James School - Site E	23-Jan-18	< 1																		Middle fountain of lower set of trio unit in school yard and near to Girls' bathroom at south exit			
Catholic	Saint Monica School	Saint Monica School - Site A	31-Jan-18	2.2																		Drinking fountain at fountain-bottle filling unit next to restroom outside gym in basement of Main B			
		Saint Monica School - Site B	31-Jan-18	2.3																		Lower drinking fountain next to ramp in kindergarten/extended care room in basement of Main Building			
		Saint Monica School - Site C	31-Jan-18	< 1																		Far-right drinking fountain of triple fountain unit on right side in Upper Yard outside Main Buildin			
		Saint Monica School - Site D	31-Jan-18	1.8																		Far-right drinking fountain of quadruple-fountain unit in Lower Yard outside Main Building			
		Saint Monica School - Site E	31-Jan-18	5.1																		Sink faucet (cold water) of sink-bottle filling unit in kindergarten/extended care room in basement			
Catholic	Saint Vincent de Paul	Saint Vincent de Paul - Site A	15-Feb-18	< 1																		Right Drinking Fountain against wall of Main Building next to stairs lead to main entrance on parkin			
		Saint Vincent de Paul - Site B	15-Feb-18	< 1																		Bottling filling station at fountain-filling station near east stairwell in cafeteria on lower level			
		Saint Vincent de Paul - Site C	15-Feb-18	< 1																		Drinking fountain next to Boys' Restroom near 3rd Grade calssroom in Maon Building			
		Saint Vincent de Paul - Site D	15-Feb-18	12																		Drinking fountain between Boys' Restroom and 5th Grade Classroom on 2nd floor of Junior High Buildin			
		Saint Vincent de Paul - Site E	15-Feb-18	< 1																		Lower drinking fountain against west outside wall of gym building in parking lot			
Catholic	St. Brendan Elementary	St. Brendan Elementary - Site A	2-Feb-18	< 1																					

School District Type	School Name	SamplePointName (Source_Name)	Initial Result		Repeat Result		Confirmatory		2nd Confirmatory		For Confirmatory Level >15 ppb, Investigative Sample Result										Post-corrective				
			Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Sample Time for Sample #2	Sample #2 Pb (µg/L)	Sample #3 Pb (µg/L)	Sample #4 Pb (µg/L)	Sample #5 Pb (µg/L)	Sample #6 Pb (µg/L)	Sample #7 Pb (µg/L)	Sample #8 Pb (µg/L)	Sample #9 Pb (µg/L)	Sample #10 Pb (µg/L)	SampDesc_(Location_Comments)	Comments	Sample Date	Pb (µg/L)
		St. Brendan Elementary - SPECIAL SAMPLE	10-Feb-18	1.3																		Site 2: Complab - Corner Sink (init) Site 3: Complab - Children's BR Sink (init) Site 4: Princ.Offc - BR Sink (init) Site 5: Princ.Offc - Closet Sink (init) Site 6: Faculty Room Sink (init) Site 7: Faculty Rm Refrig Water Disp (init) Site 8: Boys Shltr BR Sink #1[L] (init) Site 9: Boys Shltr BR Sink#2[C] (init) Site 10: Boys Shltr BR Sink#3[R] (init) Site 11: Girls Shltr BR Sink#1[L] (init) Site 12: Girls Shltr BR Sink#2[C] (init) Site 13: Girls Shltr BR Sink#3[R] (init) Site 14: Extended Care Sink (init) Site 15: ScienceLab Sink (init) Site 16: UpperFl. Boys BR Sink (init) Site 17: Upper Fl. Girls BR Sink (init) BBF_POE[init] - SUMS (St Brendan NearestTCR Summit System)	School rep could not confidently identify nearest sample to POE on 2/10/18		
Catholic	St. Gabriel Elementary	St. Gabriel Elementary - Site A	22-Nov-17	1.57																		St. Gabriel ES site A- Drinking fountain between main entrance and Room 3B on 1st floor of Main Bull			
		St. Gabriel Elementary - Site B	22-Nov-17	< 1																		St. Gabriel ES site B- Drinking fountain between Room 5A and Room 7B on 2nd floor of Main Building			
		St. Gabriel Elementary - Site C	22-Nov-17	< 1																		St. Gabriel ES site C- Drinking fountain between Girls Bathroom and exit to lower school yard in bas			
		St. Gabriel Elementary - Site D	22-Nov-17	< 1																		St. Gabriel ES site D- Right (when facing) drinking fountain in preschool small yard between Main Bu			
		St. Gabriel Elementary - Site E	22-Nov-17	2.28																		St. Gabriel ES site E- Right (when facing) drinking fountain across from north end of Church and nex			
Catholic	St. Ignatius College Preparatory	St. Ignatius College Preparatory - Site A	29-Mar-18	22	10-Apr-18	13	19-Apr-18	17														2xDFFS(Filling Station); Cafeteria - SE			
		St. Ignatius College Preparatory - Site B	29-Mar-18	1.3																		3xDFFS(Filling Station); AB 1st Flr. OUTSIDE Rm117			
		St. Ignatius College Preparatory - Site C	29-Mar-18	< 1																		3xDFFS(Filling Station); AB 1st Flr. OUTSIDE Rm105			
		St. Ignatius College Preparatory - Site D	29-Mar-18	< 1																		2xDFFS(Filling Station); South Gym - NE corner			
		St. Ignatius College Preparatory - Site E	29-Mar-18	5.1																		3xDFF(Leftmost); Stadium/Field(NW) NEAR track shed			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		McGucken 4th kitchen			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	33																		McGucken 4th kitchen			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	18																		McGucken 406			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	32																		McGucken 206			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	1																		McGucken 217			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	2.6																		McGucken conference room			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		McGucken dining room			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Kitchen vegetable sink			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Kitchen kettle			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Kitchen coffee station			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Commons NW			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Commons NE			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Campus Ministry E			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Campus Ministry W			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 101			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 1st Floor women's lounge			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 2nd Floor women's lounge			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 2nd north hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 2nd north hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	1.7																		Academic 2nd south hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 2nd south hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Academic 2nd south hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	5.5																		Academic 3rd south hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	4.4																		Academic 312			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	2.4																		Academic 301			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	2.2																		Academic 3rd north hall			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Student center by athletics			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Student center by athletics			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	3.2																		Cowell north lobby			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	1.2																		Cowell south lobby			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	2.4																		Cowell snack shack			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		McCullough SE			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		McCullough SW			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Pool NW			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Pool SW			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Upper practice field			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Old weight room			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Locker room hallway			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		New weight room- bottle filling station			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		New weight room			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Concession stand on field			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		Concession stand on field-DF Lower			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	2.1																		Concession stand			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		2nd Floor choral wing			
		St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18	< 1																		2nd Floor choral wing			

School District Type	School Name	SamplePointName (Source_Name)	Initial Result		Repeat Result		Confirmatory		2nd Confirmatory		For Confirmatory Level >15 ppb, Investigative Sample Result										Post-corrective				
			Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Pb (µg/L)	Sample Date	Sample Time for Sample #2	Sample #2 Pb (µg/L)	Sample #3 Pb (µg/L)	Sample #4 Pb (µg/L)	Sample #5 Pb (µg/L)	Sample #6 Pb (µg/L)	Sample #7 Pb (µg/L)	Sample #8 Pb (µg/L)	Sample #9 Pb (µg/L)	Sample #10 Pb (µg/L)	SampDesc_(Location_Comments)	Comments	Sample Date	Pb (µg/L)
		St. Ignatius College Preparatory- SPECIAL SAMPLE St. Ignatius College Preparatory- SPECIAL SAMPLE	6-May-18 6-May-18 6-May-18 6-May-18 6-May-18	1.2 < 1 1.9 < 1 2.1																	McGucken Jesuit dining room Room 315 center island east sink Room 324 office sink Room LG 35 trainers room B&G shop				
Catholic	St. John Elementary School	St. John Elementary School - Site A St. John Elementary School - Site B St. John Elementary School - Site C St. John Elementary School - Site D St. John Elementary School - Site E	30-Jan-18 30-Jan-18 30-Jan-18 30-Jan-18 30-Jan-18	4.4 9.6 2.6 < 1 1.5																	Drinking fountain on right side of door inside Classroom 4 in Main Building Drinking fountain with top faucet on left side of door inside Classroom 6 in Main Building Drinking fountain with top faucet on left side of door inside Classroom 8 in Main Building Drinking fountain between trophy display and notice board under flag in gym on 1st floor of Main Bui Right drinking fountain outside gym between snack stand and ladies Room in Main Building				
Catholic	St. Paul's School	St. Paul's School - Site A St. Paul's School - Site B St. Paul's School - Site C St. Paul's School - Site D St. Paul's School - Site E	6-Feb-18 6-Feb-18 6-Feb-18 6-Feb-18	< 1 < 1 < 1 < 1																	Drinking fountain between restrooms and across from 4th grade classroom on 2nd floor of Main Buidin Drinking fountain between restrooms and across from 7th grade classroom on 3rd floor of Main Buidin DF 1st floor across from Kindergarten Drinking fountain adjacent to basketball court in gym on 1st floor of Main Building Far right fountain of triple unit on north end of playground outside Main Building	Only 4 sample taps were selected and accepted by school representative Katie Kiss on 2/9/18			
Catholic	St. Peter and Paul Elementary	St. Peter and Paul Elementary - Site A St. Peter and Paul Elementary - Site B St. Peter and Paul Elementary - Site C St. Peter and Paul Elementary - Site D St. Peter and Paul Elementary - Site E	6-Dec-17 6-Dec-17 6-Dec-17 6-Dec-17 6-Dec-17	< 1 < 1 1.6 1.3 1.1																	St. Peter & Paul ES Site A-Drinking fountain across from gym and next to cafeteria in Main building St. Peter & Paul ES Site B-Drinking fountain across from Grade 8 Classroom and next to Room 6 and Ro St. Peter & Paul ES Site C-Drinking fountain across from Grade 1 Classroom and next to closet rooms St. Peter & Paul ES Site D-Drinking fountain across from Grade 3 Classroom and next to closet rooms St. Peter & Paul ES Site E-Drinking fountain between Salesian Boys' and Girls Club building in school				
Catholic	St. Peter's School	St. Peter's School - Site A St. Peter's School - Site B St. Peter's School - Site C St. Peter's School - Site D St. Peter's School - Site E	23-Jan-18 23-Jan-18 23-Jan-18 30-Jan-18	11 1 < 1 < 1																	Left drinking fountain of trio unit between basketball courts and Boys' bathroom on courtyard Left drinking fountain of dual unit between basketball courts and Girls' bathroom on courtyard Cold water tap of sink inside teachers' lounge in Main Building Cold water faucet at kitchen sink in cafeteria	Only requested 4 sites			
Catholic	St. Philip School	St. Philip School - Site A St. Philip School - Site B St. Philip School - Site C St. Philip School - Site D St. Philip School - Site E	17-Jan-18 17-Jan-18 17-Jan-18 17-Jan-18 17-Jan-18	1.1 < 1 < 1 < 1 < 1																	Drinking fountain next to Room 1 on 1st floor of Main Building Drinking fountain in hallway left of office main door on 2nd floor of Main Building Drinking fountain below window across from Room 4 on 2nd floor of Main Building Drinking fountain in archway across from Room 5 and Room 6 on 3rd floor of Main Building Drinking fountain between computer lab and library on 3rd floor of Main Building				
Catholic	St. Stephen School	St. Stephen School - Site A St. Stephen School - Site B St. Stephen School - Site C St. Stephen School - Site D St. Stephen School - Site E	28-Feb-18 28-Feb-18 28-Feb-18 28-Feb-18 28-Feb-18	< 1 1.3 2.6 10 < 1																	Drinking fountain between Computer Lab and library on 1st floor in office wing of New Building Drinking fountain on south end of playground with single basketball court adjacent to 2nd grade clas Drinking fountain on southeast end of playground with 3 basketball courts adjacent to 4th grade and Drinking fountain between 1st grade and 2nd grade in primary grade hall of Main Building Drinking Fountain, kindergarten classroom				
Catholic	St. Thomas More	St. Thomas More - Site A St. Thomas More - Site B St. Thomas More - Site C St. Thomas More - Site D St. Thomas More - Site E	28-Nov-17 28-Nov-17 28-Nov-17 28-Nov-17 28-Nov-17	< 1 1.3 < 1 < 1 1.5																	St. Thomas More Site A-Drinking fountain in 1st floor hallway adjacent to teachers' lounge in Main B St. Thomas More Site B-Sink faucet (cold water) in teacher's lounge on 1st floor of Main Building St. Thomas More Site C-Upper drinking fountain outside Gym adjacent to restrooms on 1st floor of Mai St. Thomas More Site D-Lower (right) drinking fountain between restrooms on north side of playground St. Thomas More Site E-Drinking fountain next to 6th grade classroom across 7th grade classroom on 2				
Catholic	St. Thomas the Apostle School	St. Thomas the Apostle School - Site A St. Thomas the Apostle School - Site B St. Thomas the Apostle School - Site C St. Thomas the Apostle School - Site D St. Thomas the Apostle School - Site E	22-Nov-17 22-Nov-17 22-Nov-17 22-Nov-17	< 1 < 1 < 1 < 1																	St. Thomas Apostle School Site A- Faucet of sink-faucet unit in kitchen next to preschool hall of pr St. Thomas Apostle School Site B- Drinking fountain of water filling station between Boys Bathroom a St. Thomas Apostle School Site C- Middle drinking fountain in school yard along pathway between Main St. Thomas Apostle School Site D- Drinking fountain between Room 2 and Kindergarten Room in Main Bui	Principal Borelli confirmed that 4 sites was sufficient			
Catholic	Star of the Sea School	Star of the Sea School - Site A Star of the Sea School - Site B Star of the Sea School - Site C Star of the Sea School - Site D Star of the Sea School - Site E	6-Dec-17 6-Dec-17 6-Dec-17 6-Dec-17 6-Dec-17	1.6 2.4 1 1.7 29	12-Dec-17	340	17-Jan-18	140			17-Jan-18	9:33	80	85	60	99	23	13	9.1	7	13	Star of the Sea site A-Far left drinking fountain near Boys' Bathroom by south exit in school yard Star of the Sea site B-Far right drinking fountain near Girls' Bathroom by north exit in school yard Star of the Sea site C-Drinking fountain between Grade 2 Classroom and Principals Office on 2nd flo Star of the Sea site D-Drinking fountain between Grade 7 Classroom and Grade 7/8 English Classroom o Star of the Sea site E-Drinking fountain between Boys Bathroom and Girls Bathroom across from north			
		Star of the Sea School - SPECIAL SAMPLE Star of the Sea School - SPECIAL SAMPLE	20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18 20-Jan-18	< 1 < 1 7.6 < 1 7.1 < 1 1.1 < 1 < 1 < 1 2.2																	2nd floor faculty bathroom 3rd floor faculty bathroom Main Level Girls Bathroom sink #1 left; with soap dispenser Main Level Girls Bathroom sink#2 middle Main Level Girls Bathroom sink# 3 right Kitchen sink SubLevel Annex Bldg Kitchen basin SubLevel Annex Bldg; faucet; cold LEFT Kitchen sink SubLevel Annex Bldg; shower faucet[bypass used]; cold Boys bathroom Main level, sink tap# 1/left Boys bathroom Main level, sink tap #2/middle Boys bathroom Main level, sink tap # 3/right 3rd floor Main building; hallway sink	Used on initial sampling date of 1/20/18. Resample only if school calls			